CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM LISTING SERVICE



LISTING No. 3774-0923:0102

CATEGORY: 3774 -- ELECTRIC LOCKS

- LISTEE: Securitron Magnalock10027 S. 51st St., Ste. 102, Phoenix, AZ 85044 Contact: Josh Peabody (775) 355-5626 Fax (775) 355-5638 Email: jpeabody@assaabloyems.com
- DESIGN: Models EXD-1 and EXD-1F exit delay systems. Unit consists of the following subassemblies: BPS-12, -1, -3, -4.5, -6, -9, -15, BPS-24, -1, -2, -3, -4, -6, -10, BPSM-12, -6, -9, -15, BPSM-24-4, -6, or -10 Class 2 Output Power Supplies; MK or MKN Mortise Keyswitch; TSB-1, TSB-3, TSB-3B, 3100, 3300, 3600, 3700, LMS-1, LML-1, -2, TSH-BK, -CL, MXD-32, -62 exit device, TDM, TDMT, XDT logic timers and Series 32, 34, 38, 62, 68, 82, and SAM Series Locking Devices, and LCP Lock Control Panel. Refer to listee's data sheet for detailed product description and operational considerations.

RATING: Input: 120VAC, Output: 12 or 24 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating, and UL label.

- APPROVAL: Listed as electric special egress-control device. Model EXD-1 is intended for installation on non-fire rated doors. Model EXD-1F is intended for installation on wood or metal fire rated doors. Authority having jurisdiction shall be consulted prior to installation.
- NOTE: Both models may be used in conjunction with a separately listed fire alarm control panel, however, the units must be connected via the panels dry relay contacts designated as "Auxiliary". Connection to the fire alarm control unit "trouble" or "alarm relay" contacts is NOT approved.

Updated 08-05-10 fm



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued:

July 01, 2012

Listing Expires June 30, 2013

Authorized By:

Fire Engineering Division

JASON DEWITT, Deputy State Fire Marshal

Page 1 of 1