

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 3774-0923:0103

Page 1 of 1

CATEGORY: 3774 -- ELECTRIC LOCKS

LISTEE: Securitron Magnalock 10027 S. 51st St., Ste. 102, Phoenix, AZ 85044
Contact: Josh Peabody (775) 355-5626 Fax (775) 355-5638
Email: jpeabody@assaabloyems.com

DESIGN: Models XP-1 and XP-1F exit locking system. System consists of the following subassemblies:
BPS-12, -1, -3, -4.5, -6, -9, -15; BPS-24, -1, -2, -3, -4, -6, -10; BPSM-12-6, -9, -15; or BPSM-24-4, -6, -10 Class 2 output power supplies
TSB-1, TSB-3, or XMS exit device (XP-1F requires 3100, 3300, 3600, 3700)
Series 32, 34, 38, 62, 68, and 82 or SAM Series locking device
Models TSH-BK and TSH-CL Touch Sense Handle exit device
LCP Lock Control Panel

Refer to listee's data sheet for detailed product description and operational considerations.

RATING: Input: 120 VAC, Output: 12 or 24 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances, and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating, and UL label.

APPROVAL: Listed as electric locking system. Model XP-1 is intended for installation on non-fire rated doors. Model X-1F is intended for installation on wood or metal fire rated doors. Authority having jurisdiction shall be consulted prior to installation.

NOTE: Both models may be used in conjunction with a separately listed fire alarm control panel, however, the units must be connected via the panels dry relay contacts designated as "Auxiliary". Connection to the fire alarm control unit "trouble" or "alarm relay" contacts is **NOT** approved.

*Rev. 04-19-2005



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2012**

Listing Expires **June 30, 2013**

Authorized By: **JASON DEWITT, Deputy State Fire Marshal**
Fire Engineering Division